


DETAIL: KEYED TEST DEPLOY SWITCH SCALE: 3" = 1'-0"



DETAIL: DOOR ACTIVATION SWITCH SCALE: 3" = 1'-0"



287 N. Maple Grove Boise, ID 83704 800.574.0330 www.smokeguard.com

M2100 ELECTRICAL NOTES:

1. SMOKE GUARD TO PROVIDE:

a. MAIN CONTROLLER STATION
b. END—OF—LINE DIODE

2. ALL REMAINING ELECTRICAL BY OTHERS. 3. DEFAULT LOCATION OF MAIN MOTOR IS

3. DEFAULT LOCATION OF MAIN MOTOR IS RIGHT SIDE VIEWED FROM FRONT ELEVATION. LEFT SIDE IS OPTIONAL UPON REQUEST.
4. CONTROLLER DIMENSIONS ARE
18"x14.25"x 6", REFER TO SUPPLEMENTARY DOCUMENTATION FOR WIRING SPECIFICS & MOUNTING DETAILS.

		REVISION
REVISION NUMBER	REVISION DATE	REVISION DESCRIPTION
01	7.27.19	INITIAL RELASE

QUOTE: CONFIGURATION: PROJECT: DIST.:

DESIGN SET: D1
MODEL: M2100
FLECTRICAL DIAGRAM

SINGLE CONTROLLER DRAWN: TM

B

